

**June 2013**

Flow Limit	In Effect when Temperature is:	Number of Days Flow Limit was in Effect
43.2 MGD	Under 65°F	5
50 MGD	Between 65°F and 70°F	11
60 MGD	Over 70°F	14
Total Days		30